

THIS IS A TWO-SIDED DOCUMENT

 Adirondack Park Agency PO Box 99 · 1133 NYS Route 86 Ray Brook, NY 12977 Tel: (518) 891-4050 www.apa.ny.gov	APA General Permit/Order 2019G-1	Permit #: 2025-0165
	Certification for the Replacement of Certain Utility Poles	

This certification under General Permit 2019G-1 is granted to National Grid, authorizing the replacement of utility poles as described herein in the Town of Crown Point, Essex County.

All terms and conditions of this certification shall apply to the applicant and any individual, contractor, municipality, or other entity undertaking the authorized work on the project site.

This certification does not grant any right to trespass upon the lands or interfere with the riparian rights of others, nor does it authorize the impairment of any easement, right, title, or interest in real or personal property.

Nothing contained in this certification shall be construed to satisfy any legal obligations of the applicant to comply with all applicable laws and regulations or to obtain any governmental approval or permit from any entity other than the Agency, whether federal, state, regional, or local.

PROJECT DESCRIPTION AS PROPOSED

The project as conditionally approved herein involves replacement of 16 existing utility poles ranging from 34 to 38.5 feet above grade with 16 utility poles measuring 43 feet above grade.

The project is shown on a seven-page set of plans titled "National Grid WR 31041915", prepared by National Grid, and dated July 18, 2025 (Site Plan).

A reduced-scale copy of the Site Plan for the project is attached to this certificate for easy reference. The original, full-scale maps and plans described in this paragraph are the official plans for the project, with copies available upon request from Adirondack Park Agency headquarters in Ray Brook, New York.

CONDITIONS

1. The height and location of the replacement utility poles and any associated vegetative cutting and maintenance shall comply with all applicable utility laws, regulations, safety requirements, and company specifications.
2. For projects involving wetlands:
 - a. Whenever practicable, access through wetlands shall occur on frozen ground and with the use of wide-tracked vehicles.

- b. All activities shall occur in compliance with the "Best Management Practice for Preventing the Transportation of Invasive Plant Species," published by Environmental Energy Alliance of New York, 4/26/2012.
 - c. No temporary access structure, including bog mats and work pads, shall be located within a wetland for more than 30 days.
 - d. Existing poles to be replaced shall be removed completely from the wetland, including the portion of the pole that was below grade.
 - e. If any hole left after removal of a pole or created for a replacement pole is to be backfilled with gravel or other ballast, the top six inches shall be covered with organic soil and the final elevation shall be the same as the surrounding wetland surface.
 - f. The total area of wetland disturbance shall be limited to that necessary for replacement of the utility poles.
3. When brought from off-site, all vehicles, construction equipment, and hand excavation tools to be used on the project site shall be clean and free of soil, mud, or other similar material. If washed on the project site, equipment shall be washed in one location to prevent the distribution of propagules among different wash sites. All vehicles, construction equipment, and hand excavation tools used in areas that may contain existing invasive species shall be thoroughly cleaned prior to moving to other areas.
4. The Agency may conduct on-site investigations, examinations, and evaluations as it deems necessary to ensure compliance with the terms and conditions of this certification.

CERTIFICATION issued this 24th day
of July, 2025.

ADIRONDACK PARK AGENCY


BY: John M. Burth
Deputy Director, Regulatory Programs

STATE OF NEW YORK
COUNTY OF ESSEX

On the 24th day of July in the year 2025, before me, the undersigned, a Notary Public in and for said State, personally appeared John M. Burth, personally known to me or proved to me on the basis of satisfactory evidence to be the individual whose name is subscribed to the within instrument and acknowledged to me that they executed the same in their capacity, and that by their signature on the instrument, the individual, or the person upon behalf of which the individual acted, executed the instrument.

Stephanie L. Petith
Notary Public

Stephanie L. Petith
Notary Public, State of New York
Reg. No. 01PE6279890
Qualified in Franklin County
Commission Expires April 15, 2029



RECEIVED

Date: July 18, 2025

National Grid (M/R 31041915)
Replace poles on Ferry Road in Crown Point,
Essex County, NY.

- Pole 16 existing height: 34'
replacement height: 43'
- Pole 16-1 existing height: 34'
replacement height: 43'
- Pole 16-2 existing height: 34'
replacement height: 43'
- Pole 16-3 existing height: 34'
replacement height: 43'
- Pole 19 existing height: 34'
replacement height: 43'

GIS: 43.951007576935825, -73.4193613827803





National Grid (NWR 31041915)

Replace pole on Ferry Road in Crown Point,
Essex County, NY.

Pole 32 existing height: 34'
replacement height: 43'

Location is within a potential habitat for Indiana
bats.

GIS: 43.95076960204972, -73.42767319261783



National Grid (W/R 31041915)

Replace pole and install new poles on Creek Road and Main Street in Crown Point, Essex County, NY. Install new poles 39.5A and 39.5 on Creek Road - Proposed height: 47.5' (Over 40 ft permit submitted separately).

Pole 39 existing height: 38.5' replacement height: 43'

Pole 2.5 on Main Street - Proposed height 43' (Over 40 ft permit submitted separately).

GIS: 43.95133011928327, -73.4319986527584



National Grid (WR 31041915)

Replace pole on Creek Road in Crown
Point NY.

Pole 53 existing height: 38.5
replacement height: 43'

GIS: 43.952195878942305, -73.43949008631673



National Grid (NVR 31041915)

Replace poles on Pearl Street in Crown Point,
Essex County, NY

Pole 24 existing height: 34'
replacement height: 43'

Pole 25 existing height: 34'
replacement height: 43'

GIS: 43.944833396910894, -73.45332702385141



National Grid (W/R 31041915)

Replace poles on Pearl Street in Crown Point,
Essex County, NY

Pole 28 existing height: 38.5'
replacement height: 43'

Pole 29 existing height: 38.5'
replacement height: 43'

Pole 30 existing height: 38.5'
replacement height: 43'

GIS: 43.942426498853024, -73.45581499136969



National Grid (W/R 31041915)

Replace poles on Pearl Street in Crown Point,
Essex County, NY

Pole 32 existing height: 38.5'
replacement height: 43'

Pole 33 existing height: 38.5'
replacement height: 43'

Pole 34 existing height: 38.5'
replacement height: 43'

GIS: 43.938613846372526, -73.45795847116028